

Eyewashes must be inspected weekly. Follow the directions below for how to perform the eyewash test effectively.

- 1. Visually inspect the eyewash for any missing parts (e.g. caps, nozzles, etc.)
- 2. Activate the eyewash and run for at least three minutes noting if the following are adequate: Spray pattern, flow, and temperature
- 3. Sign off or report any deficiencies to fmp.service.centre@carleton.ca or at ext. 3668.

NAME	DATE	NAME	DATE

