

Office Inspection Checklist

GENERAL SAFETY	
Floor and aisles are cluttered and present tripping hazards.	
Heavy items are stored on upper shelves.	
Build up of paper and other combustible materials present fire hazard.	
Items are stored in hallways (e.g. bicycles, file boxes, unused equipment).	
EMERGENCY PREPAREDNESS & FIRE SAFETY	
Egress path is obstructed.	
Users do not know their Safe Destination Sites.	
Fire extinguisher is inaccessible.	
Fire extinguisher has not been inspected on monthly basis.	
Objects within 18" of sprinklers.	
No first aid kit available.	
First aid kit has inappropriate or missing supplies.	
Users not aware how to report incidents or injuries.	
PHYSICAL HAZARDS	
Noise levels are unacceptable for the activities conducted and safety procedures in place.	
Step ladder is not available for reaching overhead storage, if any.	
Shelves are overloaded.	
File cabinet doors are left open, posing risk of injury.	
Lighting is inadequate.	
Flooring is in poor condition and presents a tripping hazard.	
Chemicals or other hazardous materials are present in office space.	
ELECTRICAL HAZARDS	
Electrical outlets and switches are missing cover plates.	
Outlets are overloaded.	
Evidence of burn marks near electrical outlets or switches.	
Electrical cords and plugs are in poor condition (e.g. frayed, exposed wire, broken ground prong).	
Power cords are run under doors, carpets or through ceilings.	
Power bars are connected in series.	
Evidence that extension cords are used long-term.	
Equipment is not certified by the Electrical Safety Authority (ESA) and does not bear appropriate safety	
markings CSA or otherwise).	

